Eye Wash & Shower Stations

Safety Log Protocol and Record of Maintenance

Eye Wash & Shower Inspection Form

According to the American National Standard Institute's (ANSI) Emergency Eye Wash and Shower equipment standard Z358-1-2014, weekly flushing testing for proper operation on the eyewash and shower station must be performed and documented. Note that OSHA incorporated the ANSI standard with respect to eye wash and shower station inspection.

Procedure: **Weekly** flush the eye wash and shower stations to ensure it is working properly and is unobstructed and accessible. Document the inspection noting any deficiencies or problem. Contact: **Nikki Handy, Lab Technician, (202) 250-6395 and nikki.handy@howard.edu**, or the Office of Environmental Health & Safety to correct any problem.

OSHA Standard

1910.151(c)

Number:	1910.1	<u>51(c)</u>			
Date	Eye Wash or Shower	Working order Y/N	Accessible unobstructed (Y/N	Initials	Comments/Actions needed
Example					
08/14/2019	Eye wash	Y	Y	NRH	Room 312- 4 sinks, 3rd sink- Low water pressure