



Eye Wash & Shower Stations

Safety Log protocol and Record of Maintenance

Eye Wash & Shower Inspection Form

According to the American National Standard Institute’s (ANSI) Emergency Eye Wash and Shower equipment standard Z358-1-2014, weekly flushing testing for proper operation on the eyewash and shower station must be performed and documented. Note that OSHA incorporated the ANSI standard with respect to eye wash and shower station inspection.

Procedure: **Weekly** flush the eye wash and shower stations to ensure it is working properly and is unobstructed and accessible. Document the inspection noting any deficiencies or problem. Contact: **(INPUT the contact person information here name, title, phone number and email address)**, or the office of EH&S, HU to correct any problem.

OSHA Standard Number: [1910.151\(c\)](#)

Date	Eye Wash or Shower	Working order Y/N	Accessible unobstructed (Y/N)	Initials	Comments/Actions needed
	Eye wash				
	Shower				

***All logs must be submitted to the Office of Environmental Health and Safety every Friday by COB:**

1. Via email to Zondi.Bears@howard.edu or
2. Hand delivered to the Howard Service Center located at 2244 10th Street NW suite 208 (Attn.: Ms. Zondi Bears)